

**Drinking Water Quality and Compliance  
For RESORT VILLAGE OF THODE  
2017 Annual Notice to Consumers**

**Introduction**

The Water Security Agency (WSA) requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Permit to Operate a waterworks. The following is a summary of the Resort Village of Thode water quality and sample submission compliance record for the Jan. 1<sup>st</sup> to Dec. 31<sup>st</sup> 2017 time period. This report was completed on January 15, 2018. Readers should refer to the Agency's Municipal Drinking Water Quality Monitoring Guidelines, November 2002, EPB 202 for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the Agency's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: [http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index\\_e.html](http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html).

**Water Quality Standards**

**Bacteriological Quality**

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform and Background Bacteria	0 Organisms/100 mL Less than 200/100 mL	52	52	0

**Water Disinfection –**

**Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples**

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	1.01 - 1.86	-	52	52	100%

**Water Disinfection – Total Chlorine Residual for Water Entering Distribution System from Waterworks Records-From Water Treatment Plant Records**

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Total Chlorine Residual	at least 0.5	1.37 - 1.98	365	0

Water is supplied by the City of Saskatoon and is chloraminated so there is rarely a free chlorine residual. The system operates on total chlorine residual.

**Chemical – Health Category**

All waterworks serving less than 5000 persons are required to submit water samples for WSA's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

\* Water is supplied by the City of Saskatoon. Results from these tests can be seen at [www.saskatoon.ca](http://www.saskatoon.ca)

**Chemical – Trihalomethanes (THMs)**

\* Water is supplied by the City of Saskatoon. Results from these tests can be seen at [www.saskatoon.ca](http://www.saskatoon.ca)

**Chemical - Haloacetic Acids**

Parameter	Test Level Limit (mg/L)	Range	# Tests Performed	# Tests Not Meeting Requirements
Total Haloacetic Acids	0.08	0.023	1	0

**General Chemical**

All waterworks serving less than 5000 persons are required to submit water samples for WSA's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO<sub>3</sub>), magnesium, sodium, sulphate and total dissolved solids.

\* Water is supplied by the City of Saskatoon. Results from these tests can be seen at [www.saskatoon.ca](http://www.saskatoon.ca)

\*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO<sub>3</sub>, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

More information on water quality and sample submission performance may be obtained from:

**Resort Village of Thode**  
Box 202  
DUNDURN, SK. S0K 1K0  
(306) 492-2259 Fax (306) 492-2068  
Email [thode@explornet.ca](mailto:thode@explornet.ca)